



Reg. No. 041/P-007

NOTIFIED BODY No. 1396
Osloboditeľov 282, 059 35 Batizovce, Slovakia
tel. +421 52 7752298 fax. +421 52 7881412 <http://www.fires.sk>



Certificate of constancy of performance

1396-CPR-0096

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Double flap natural smoke and heat exhaust ventilator, type FUMETICA

a dual purpose natural smoke and heat exhaust ventilator, type B - device for the movement of hot gases out of the construction works which is able to be opened into its fire open position and closed remotely, and which is intended to use for comfort ventilation, used on conditions described in the Assessment and verification of constancy of performance No. C1396/15/0006/4003/SC issued by FIRES, s.r.o., Notified Body 1396 on 14.04.2015,

produced by

**Brakel Aluminium b.v.
Linie 48, 5405 An Uden, Netherlands**

and produced in the manufacturing plant

**Brakel Aluminium b.v.
Linie 48, 5405 An Uden, Netherlands**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 12101-2: 2003

under system 1 for the performances set out in this certificate are applied and that the construction product fulfils all the prescribed requirements for these performances.

This certificate was first issued on 14.04.2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performances of the declared essential characteristics, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body.

Batizovce, 14.04.2015



Ing. Mária Gašperová
Head of Product Certification Body

065916

FIRES 136a/C-29/07/2014-E